

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	SRNE Solar Co., Ltd	Manufacturer:	SRNE Solar Co., Ltd
Address:	4-5F,13A Wutong Island,Neihuan Rd, Xixiang, Bao`an, SHENZHEN Guangdong 518100	Address:	Room 301, Building 5, Fuxing Road, No. 36, Chang'an Town, Dongguan City, Guangdong
Country:	China	Country:	China
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Intertek Testing Services (Shanghai FTZ) Co., Ltd		
Control Number:	<u>5012002</u>	Authorized by:	 _____
			for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3+R:19May2023]
	Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]
Standard(s):	Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4+U1]
	IEEE Standard for Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces [IEEE 1547:2018]
	IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Energy Resources with Electric Power Systems and Associated Interfaces [IEEE 1547.1:2020]
	Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]
Product:	Grid Support Utility Interactive Inverter (Non-Isolated inverter)
Brand Name:	SRNE

Models:

HESP followed by 4880, 48100 or 48120; followed by U200-H.
SEI- followed by 8K, 10K or 12K; followed by -UP.
HEBP followed by 4880, 48100 or 48120; followed by U200-H.
SBK- followed by 8K, 10K or 12K; followed by -UP.